

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHEISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, Troja, 182 00 Praha 8

CERTIFICATE

No.: 1250206

Product: Lightning protection connectors

Type: 101112, 101212, 101312, 101412
101512, 101612, 101712, 101812
111212, 111112, 111312, 111412

Rating: Class N, FeZn

Ordering firm: GROMTOR SP Z.O.O.
ul. KRAKOWSKA 180/106, 52-015 Wrocław, Poland

Manufacturer: GROMTOR SP Z.O.O.
ul. KRAKOWSKA 180/106, 52-015 Wrocław, Poland

Factories: GROMTOR SP Z.O.O.
ul. Glowna 6, 55-010 Swieta Katarzyna (Wrocław), Poland

Trade mark:

The test results are stated in the test-report No.: 250967-01/01 of: 22.05.2025

A sample of the product was found to be in conformity with:
ČSN EN IEC 62561-1 ed. 3:2024 (idt EN IEC/IEC 62561-1:2023)

Other data:

The validity of the certificate is limited to: 25.05.2028

26.05.2025

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



250967-01